

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30/05/2025

It is certified that an inspection team headed by B.K. Soni, Medical Officer
AGRA.

(Name of Officers with designation) from C.H.C. SHAMSHABAD, PHED

inspected the ARYABHATTA PUBLIC SCHOOL, KHERA NAWADA, GADI JAHAN
SINGH ROAD, SHAMSHABAD, AGRA, 283125.

(Name & Address of the school) on 27/05/25....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 23/05/25..... dated 29/05/25

of JALKAL VIBHAG, NAGAR NICAM (PHED) Lab certified that

the ARYABHATTA PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30/05/2026

Signature with Seal:

Name: B.K. SONI 30/05/2025

Designation: MEDICAL OFFICER

Name & Address of the Office / Department: C.H.C.

SHAMSHABAD, AGRA

To ARYABHATTA PUBLIC SCHOOL
KHERA NAWADA, GADI JAHAN SING ROAD
(Name & Address of the Institution) SHAMSHABAD, AGRA

30/05/2025
Medical Officer
C.H.C. Shamshabad, AGRA

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

30/05/2025
Medical Officer
C.H.C. Shamshabad, AGRA



कार्यालय प्रयोगशाला (मु.) , जलकल विभाग, नगर निगम आगरा

OFFICE OF LABORATORY, JALKAL VIBHAG, NAGAR NIGAM, AGRA

Chemical Water Analysis Test Report

Source of Sample — Submersible

Agency/Deptt.-M/s Aryabhakti Public School, Khera-Nawada, Gadi Jahan Singh Road, Shamshabad, Agra-283125

Date of Collection: 23-05-2025 (09.15 am)

Date of Received : 23-05-2025 (01.30 pm)

Sr. No	Parameters	IS : 10500(2012)	Result	Unit
1	Turbidity	1.0-5.0	1.2	NTU/1
2	Colour	5.0-15.0	NIL	P.Scale
3	pH	6.5-8.5	7.32	-
4	Total Dissolved Solids (TDS)	500.2-2000.0	1400	Mg/L
5	Total Hardness as CaCO ₃	200-600	440	Mg/L
6	Calcium Hardness	-	238	Mg/L
7	Magnesium Hardness	-	202	Mg/L
8	Total Alkalinity (M) as CaCO ₃	200.0-600.0	360	Mg/L
9	Chlorides	250.-1000	252	Mg/L
10	Sulphate	200-400	248	Mg/L
11	Nitrates	45-100	NIL	Mg/L
12	Flourides	1.0-1.2	1.0	Mg/L
13	Calcium as Ca ⁺⁺	75.0-200.2	95.2	Mg/L
14	Magnesium as Mg ⁺⁺	30.0-100	49.28	Mg/L
15	Iron as Fe	0.30-1.0	0.40	Mg/L
16	Manganese	0.1-0.3	0.30	Mg/L
17	Ammonia AND DEPOSITED BY THE PARTY ITSELF	0.1-0.5	NIL	Mg/L

Bacteriological Test Report

THE SAMPLE IS COLLECTED AND
DEPOSITED BY THE PARTY ITSELF

			Result	
1	Coliform	NIL	NIL	CFU/100 MI
2	E.Coli	NIL	NIL	CFU/100 MI

Remark:- The result conforms to standard IS : 10500 (2012) hence potable.

14
Chief Chemist
2025 Sansthan, Agra

Chief Chemist

Jalkal Vibhag, Nagar Nigam, Agra